



LEAD AND COPPER 90th PERCENTILE SUMMARY¹

Water System Number: NC0118025

Date: SEPT 2019

System Name: TOWN OF LONGVIEW
9/30/2019

Compliance Period: 6/1/2019 to

Monitoring Frequency: E3YR

90th Percentile Level = <0.003			
No.	Location ³ Code	Tier/Target Category	Lead ² mg/l
1	524	Tier 1	<0.003
2	525	1	<0.003
3	526	1	<0.003
4	531	1	<0.003
5	537	1	<0.003
6	J02	1	<0.003
7	J03	1	<0.003
8	J04	1	<0.003
9	J07	1	<0.003
10	J12	1	<0.003
11	J14	1	<0.003
12	J17	1	<0.003
13	J21	1	<0.003
14	J22	1	<0.003
15	J27	1	<0.003
16	J28	1	<0.003
17	J40	1	<0.003
18	J42	1	<0.003
19	J43	1	<0.003
20	JH1	1	<0.003

90th Percentile Level = <0.050			
No	Location ³ Code	Tier/Target Category	Copper ² mg/l
1	525	Tier 1	<0.050
2	526	1	<0.050
3	531	1	<0.050
4	537	1	<0.050
5	J02	1	<0.050
6	J03	1	<0.050
7	J04	1	<0.050
8	J07	1	<0.050
9	J12	1	<0.050
10	J14	1	<0.050
11	J17	1	<0.050
12	J21	1	<0.050
13	J22	1	<0.050
14	J27	1	<0.050
15	J28	1	<0.050
16	J40	1	<0.050
17	J42	1	<0.050
18	J43	1	<0.050
19	524	1	0.056
20	JH1	1	0.086